Efectis France ZI Les Nappes 149, route du Marc F-38630 LES AVENIERES VEYRINS-THUELLIN Tél: +33 (0)4 37 06 38 11

CERTIFICATE ENGLISH VERSION

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-20-003523

Only the original French edition of this procès-verbal shall be authentic. Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on October 28th, 2020

Applicant SAINT CLAIR TEXTILES

415 Avenue de Savoie

38110 SAINT CLAIR DE LA TOUR

France

Sample reference ECOMESH

Brief description provided by

the applicant

Fabric, with in the mass fire-retardant, composed of a polyester textile support of thickness and a coating of organic acrylic/polyurethane polymers with flame retardant loads,

pigments and additives.

Mass per unit area determined

by the laboratory

225 g/m² ± 10%

Thickness measured by the

laboratory

0,35 mm ± 10%

Color White

End-use condition Indoor applications type: protection grid, masking, decoration and

interior design type back of windows/ stores/ stands/ roller blind

Standard of tests:

- NF P 92-507 (2004) Building Interior fitting materials Classification according to their reaction to fire
- NF P 92-503 (1995) Reaction to fire tests Electrical burner test used for flexible materials
- NF P 92-504 (1995) Reaction to fire tests Flame persistence test and speed of the spread of flame

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report **n°EFR-20-BE-003523** from November 06th, 2020.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on January 03rd, 2021