

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-20-002504

Only the original French edition of this procès-verbal shall be authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on July 29th, 2020

This English version of an official French procès-verbal cancels and replaces the English version of the official French procès-verbal n°EFR-20-20-002504.

Review tracking :

Review index	Modification	Comment
1	Modification of the header of the model	-

Applicant

SAINT CLAIR TEXTILES
415 Avenue de Savoie
38110 SAINT CLAIR DE LA TOUR
France

Sample reference

JET TEX ACOUSTIC

Brief description provided by the applicant

Polyester, with a $142 \text{ g/m}^2 \pm 10\%$ mass per unit area and a $290\mu\text{m} \pm 10\%$ thickness, with coatings of in the mass fire-retarded acrylic / polyurethane organic polymer, pigments and additives, with a $93 \text{ g/m}^2 \pm 10\%$ mass per unit area and a $40 \mu\text{m} \pm 10\%$ thickness.

Mass per unit area determined by the laboratory

$230 \text{ g/m}^2 \pm 10\%$

Thickness measured by the laboratory

$0,34 \text{ mm} \pm 10\%$

Color

White

End-use condition

Interior decoration applications / wall covering / tensioned ceiling / acoustic box / etc

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512 : 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-20-BE-002504 from August 12th, 2020.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on January 03rd, 2021