

Efectis France ZI Les Nappes 149, route du Marc F-38630 LES AVENIERES VEYRINS-THUELLIN Tél: +33 (0)4 37 06 38 11

NON OFFICIAL CERTIFICATE ENGLISH VERSION

NON OFFICIAL CERTIFICATE ENGLISH VERSION OF THE OFFICIAL FRENCH PROCES-VERBAL N° EFR-20-002504 – Révision

Only the French PROCÈS-VERBAL is legally acceptable Seul le PROCÈS-VERBAL français est légalement acceptable.

The French PROCES VERBAL is valid for 5 years starting on July 05th, 2023

This report cancels and replaces the English version of the official French procès-verbal n°EFR-20-002504

1. DOCUMENT FOLLOW-UP

| Review index | Modification | Comment | Date | | |
|--------------|--|---------|--------------------------------|----------|-------------|
| 0 | Creation of the document. | / | August 12 th , 2020 | Editor | L. BARBIER |
| | | | | Auditor | P-O. WILLAY |
| | | | | Approver | P-O. WILLAY |
| 1 | Extension of the color | / | July 11 th , 2023 | Editor | L. BARBIER |
| | range and correction of the end-use condition. | | | Auditor | L. RODIER |
| | | | | Approver | L. RODIER |

Applicant SAINT CLAIR TEXTILES

415 Avenue de Savoie

38110 SAINT CLAIR DE LA TOUR

France

Sample reference JET TEX ACOUSTIC

Brief description provided by

the applicant

Polyester, with a 142 g/m² \pm 10% mass per unit area and a 290 μ m \pm 10% thickness, with coatings of in the mass fire-retarded acrylic / polyurethane organic polymer, pigments and additives, with a 93 g/m² \pm 10% mass per unit area and a 40 μ m

± 10% thickness.

Mass per unit area determined

by the laboratory

 $230 \text{ g/m}^2 \pm 10\%$

Thickness measured by the

laboratory

0,34 mm ± 10%

Color All colors

End-use condition Interior decoration applications

Standard of tests:

- NF P 92-507 (2004) Building Interior fitting materials Classification according to their reaction to fire
- NF P 92-503 (1995) Reaction to fire tests Electrical burner test used for flexible materials
- NF P 92-504 (1995) Reaction to fire tests Flame persistence test and speed of the spread of flame

Classification obtained in the official Procès Verbal:

М1

Valid for any application for which the product is not subjected to the CE marking.



N°EFR-20-002504 - Review 1

NON OFFICIAL CERTIFICATE ENGLISH VERSION

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report **n°EFR-20-BE-002504** – **Révision 1** from July 13th, 2023.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on July 13th, 2023