

**ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-20-004268**

Only the original French edition of this procès-verbal shall be authentic.  
*Seule l'édition originale en français du présent procès-verbal fait foi.*

**The French PROCES VERBAL is valid for 5 years starting on December 10<sup>th</sup>, 2020**

This English version of an official French procès-verbal cancels and replaces the English version of the official French procès-verbal n°EFR-20-20-004268.

Review tracking :

Review index	Modification	Comment
1	Modification of the header of the model	-

<b>Applicant</b>	SAINT CLAIR TEXTILES 415 Avenue de Savoie 38110 SAINT CLAIR DE LA TOUR France
<b>Sample reference</b>	JETTEX
<b>Brief description provided by the applicant</b>	<i>Polyester fabric coated with acrylic polyurethane with in the mass fire-retardant by coating.</i>
<b>Mass per unit area determined by the laboratory</b>	250 g/m <sup>2</sup> ± 10%
<b>Thickness measured by the laboratory</b>	0,29 mm ± 10%
<b>Color</b>	White
<b>End-use condition</b>	Media for digital printing

**Standard of tests:**

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (Dec. 1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame

**Classification obtained in the official Procès Verbal:**

**M1**

**Valid for any application for which the product is not subjected to the CE marking.**

**Durability of the classification (NFP 92-512 : 1986):** Supposedly unlimited

*Taking into account the criteria resulting from the tests described in the test report n°EFR-20-BE-004268 from December 17<sup>th</sup>, 2020.*

*This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.*

*Efectis France is approved for fire reaction tests according to the Decree of December 29<sup>th</sup>, 2016 amending the Decree of February 5<sup>th</sup>, 1959.*

Les Avenières Veyrins-Thuellin, on January 03<sup>rd</sup>, 2021