

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-25-005558

Only the original French edition of this procès-verbal is authentic.  
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on December 22<sup>nd</sup>, 2025

<b>Applicant</b>	SAINT CLAIR TEXTILES 415 Avenue de Savoie 38110 SAINT CLAIR DE LA TOUR France
<b>SIREN</b>	381424712
<b>Sample reference</b>	JETUP BC
<b>Brief description provided by the applicant</b>	Polyester fabric with acrylic/polyurethane coating, flame retardant throughout, at a rate of 150 g/m <sup>2</sup> distributed over both sides.
<b>Mass per unit area determined by the laboratory</b>	295 g/m <sup>2</sup> ± 10%
<b>Thickness measured by the laboratory</b>	0,32 mm ± 10%
<b>Colour</b>	Grey on one side, white on the other
<b>End-use condition</b>	Digital printing media

**Standard of tests:**

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame

**Classification obtained in the official Procès Verbal:**

M1

**Valid for any application for which the product is not subjected to the CE marking.**

**Durability of the classification (NFP 92-512: 1986):** Supposedly unlimited

*Taking into account the criteria resulting from the tests described in the test report n°EFR-25-005558 from January 09<sup>th</sup>, 2026.*

*This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.*

*Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5<sup>th</sup>, 1959.*

Saint-Aubin, on January 09th, 2026

**Nota. - Full reproductions and photocopies of this English abstract of the official procès verbal of classification or the English version of the official procès verbal and the attached tests report are authorized.**