



This document is the translation of the French certificate n°18-00360 L on the February 19th, 2018 delivered by IFTH.

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N°18-00360 L

And appendices of 5 pages

MATERIAL presented by :

DICKSON COATING
415, avenue de Savoie
38110 Saint Clair de la Tour

TRADE NAME :

JET UP

BRIEF DESCRIPTION :

Polyester fabric with fireproofed acrylic/polyurethane coating on both sides
Nominal surface weight : 280 g/m²
Nominal thickness : 0.33 mm
Colours : white

TEST REPORT :

N° 18-00360 E1-V1 on the February 19th, 2018

TESTS :

Electrical burner test
Flame persistence test

CLASSIFICATION :

M 1

CLASSIFICATION DURATION (article 5 of appendix 2): limited 12 months from the date of the setting of the material in the regulated building, shielded from external weather conditions (material no washable and not suitable for dry cleaning)

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the February 19th, 2018

Head of Quality Management Test and trials

Laure ATCHADE
Engineer Tests and Trials

Jean-Marc ORAISON
In charge of Fire Regulation