

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-24-000485

Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on February 16, 2024

DOCUMENT FOLLOW-UP

Version	Modification	Comment	Date		
0	Document creation	/	March 08 th , 2024	Editor	L. BARBIER
				Verifier	L. RODIER
				Approver	L. RODIER

Applicant	SAINT CLAIR TEXTILES 415 Avenue de Savoie 38110 Saint Clair de la Tour France
Sample reference	JETUP
Brief description provided by the applicant	100% polyester fabric with polyurethane-acrylic flame-retardant coating on both sides
Mass per unit area determined by the laboratory	303 g/m ²
Thickness measured by the laboratory	0.33 mm
Colour	White
End-use condition	Support for digital printing

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame
- **NF P 92-505 (1995)** - Reaction to fire tests - Test used for thermal melting materials - Dripping test

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-24-000485-BE from March 08, 2024.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on March 08, 2024

Nota. - Full reproductions and photocopies of this English abstract of the official PROCES VERBAL of classification or the English version of the official PROCES VERBAL and the attached tests report are authorized.