



This document is the translation of the French certificate n° 18-01117 L on the May, 18<sup>th</sup> 2018 delivered by IFTH.

**MATERIAL REACTION TO FIRE CLASSIFICATION  
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE  
REGULATION DATED NOVEMBER 21<sup>ST</sup>, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Valid five years from issue date

**CERTIFICATE N° 18-01117 L**

And appendices of 4 pages

**MATERIAL presented by:**

**DICKSON SAINT CLAIR  
415 Avenue de Savoie  
ST CLAIR DE LA TOUR  
38357 LA TOUR DU PIN CEDEX  
FRANCE**

**TRADE NAME:**

**LAC 650 SL**

**BRIEF DESCRIPTION:**

**Polyester fabric with inherent fire resistant PVC coating on both sides  
Nominal surface weight: 680 g/m<sup>2</sup>  
Nominal thickness: 0.51 mm  
Colours: various**

**TEST REPORT:**

**N° 18-01117 E1-V1 on the May, 18<sup>th</sup> 2018**

**TESTS:**

**Electrical burner test**

**CLASSIFICATION:**

**M 2**

**CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified**

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law article L.433-3 n°2016-301 dated March 14<sup>th</sup>, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

**Issued in Lyon, France, on the May, 18<sup>th</sup> 2018**

**Sophie GUINAMAND**  
Engineer Tests and Trials

**Jean-Marc ORAISON**  
In charge of Fire Regulation