

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-23-002683 – Révision 1

Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on July 03rd, 2023

This report cancels and replaces the English version of the official French procès-verbal n°EFR-23-002683

DOCUMENT FOLLOW-UP

Version	Modification	Comment	Date		
0	Document creation	/	19/07/2023	Editor	L. BARBIER
				Verifier	L. RODIER
				Approver	L. RODIER
1	Expansion of the sample reference and incorporation of the results from report EFR-26-003410-BE Addition of the SIREN number	/	31/07/2026	Editor	L. BARBIER
				Verifier	L. RODIER
				Approver	L. RODIER

Applicant

SAINT CLAIR TEXTILES
415 Avenue de Savoie
38110 SAINT CLAIR DE LA TOUR
France

SIREN

381424712

Sample reference

LAC 920
LAC 920 SL

Brief description provided by the applicant

The fabric, with in the mass fire-retardant, is made of polyester coated with PVC on both side.

Mass per unit area determined by the laboratory

890 g/m² ± 10%

Thickness measured by the laboratory

0,72 mm ± 10%

Colour

All colors

End-use condition

Upholstery fabric

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials

Classification obtained in the official Procès Verbal:

M2

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Nota. - Full reproductions and photocopies of this English abstract of the official PROCES VERBAL of classification or the English version of the official PROCES VERBAL and the attached tests report are authorized.

*Taking into account the criteria resulting from the tests described in the test reports **n°EFR-23-002683-BE** from July 19th, 2023 and **n°EFR-26-003410-BE** from July 31st, 2026.*

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on July 31st, 2026