

**ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-23-002683**

**Only the original French edition of this procès-verbal is authentic.  
Seule l'édition originale en français du présent procès-verbal fait foi.**

**The French PROCES VERBAL is valid for 5 years starting on July 03<sup>rd</sup>, 2023**

<b>Applicant</b>	SAINT CLAIR TEXTILES 415 Avenue de Savoie 38110 SAINT CLAIR DE LA TOUR France
<b>Sample reference</b>	LAC 920
<b>Brief description provided by the applicant</b>	The fabric, with in the mass fire-retardant, is made of polyester coated with PVC on both side.
<b>Mass per unit area determined by the laboratory</b>	890 g/m <sup>2</sup> ± 10%
<b>Thickness measured by the laboratory</b>	0,72 mm ± 10%
<b>Colour</b>	All colors
<b>End-use condition</b>	Upholstery fabric

**Standard of tests:**

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials

**Classification obtained in the official Procès Verbal:**

**M2**

**Valid for any application for which the product is not subjected to the CE marking.**

**Durability of the classification (NFP 92-512: 1986):** Supposedly unlimited

*Taking into account the criteria resulting from the tests described in the test report n°EFR-23-002683-BE from July 19<sup>th</sup>, 2023.*

*This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.*

*Efectis France is approved for fire reaction tests according to the Decree of December 29<sup>th</sup>, 2016 amending the Decree of February 5<sup>th</sup>, 1959.*

Les Avenières Veyrins-Thuellin, on July 19<sup>th</sup>, 2023