

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N°18-03178 L

And appendices of 5 pages

MATERIAL presented by:

DICKSON SAINT CLAIR
415 AVENUE DE SAVOIE
ST CLAIR DE LA TOUR
38357 LA TOUR DU PIN CEDEX
FRANCE

TRADE NAME:

OPTIKA PRINT

BRIEF DESCRIPTION:

Polyester grid with inherent flame retardant PVC coating on both sides
Nominal surface weight: 300 g/m²
Nominal thickness: 0.45 mm
Colours: white

TEST REPORT:

N°18-03178 E1 - V1 on November 23rd, 2018

TESTS:

Electrical burner test
Flame persistence test

CLASSIFICATION:

M 1

**Classification valid for any application for which the product is not subjected
to the CE marking of the Construction products**


CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.


The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law article L.433-3 n°2016-301 dated March 14th, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the November 23rd, 2018



Sophie GUINAMAND
Engineer Tests and Trials



Jean-Marc ORAISON
In charge of Fire Regulation