

## ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-23-001141 – Révision 1

Only the original French edition of this procès-verbal is authentic. Seule l'édition originale en français du présent procès-verbal fait foi.

## The French PROCES VERBAL is valid for 5 years starting on April 18<sup>th</sup>, 2023

## 1. DOCUMENT FOLLOW-UP

This English version of the official French procès-verbal cancels and replaces the English version of the official French procès-verbal n°EFR-23-001141

Review index	Modification	Comment	Date		
0	Creation of the document.	/	March 22 <sup>nd</sup> , 2023	Editor	L. BARBIER
				Auditor	L. RODIER
				Approver	L. RODIER
1	Addition of the beige and grey colors.	/	April 20 <sup>th</sup> , 2023	Editor	L. BARBIER
				Auditor	L. RODIER
				Approver	L. RODIER

Applicant	SAINT CLAIR TEXTILES 415 Avenue de Savoie 38110 SAINT CLAIR DE LA TOUR France
Sample reference	RT360M1
Brief description provided by the applicant	The fabric is made of polyester, mass per unit area 150 g/m <sup>2</sup> , coated on both sides with PVC, mass per unit area 230 g/m <sup>2</sup> .
Mass per unit area determined by the laboratory	385 g/m² ± 10%
Thickness measured by the laboratory	0,36 mm ± 10%
Colour	All colors
End-use condition	Mattress

Standard of tests:

- NF P 92-507 (2004) Building Interior fitting materials Classification according to their reaction to fire
- NF P 92-503 (1995) Reaction to fire tests Electrical burner test used for flexible materials
- NF P 92-504 (1995) Reaction to fire tests Flame persistence test and speed of the spread of flame

**Classification obtained in the official Procès Verbal:** 

M1

## Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited



Taking into account the criteria resulting from the tests described in the test report **n°EFR-23-001141-BE – Révision 1** from April 20<sup>th</sup>, 2023.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5<sup>th</sup>, 1959.

Les Avenières Veyrins-Thuellin, on April 20th, 2023