



This document is the translation of the French certificate n° 16-00741 L on the 26th April, 2016 delivered by IFTH.

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation
dated November 21st, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

CERTIFICATE N° 16-00741 L

And appendices of 4 pages

MATERIAL presented by : DICKSON SAINT CLAIR
415 Avenue De Savoie
ST CLAIR DE LA TOUR
38357 LA TOUR DU PIN CEDEX
FRANCE

TRADE NAME : SUNBLOCK

BRIEF DESCRIPTION : Fabric made of polyester with flame retardant PVC coating on both sides
Nominal surface weight : 850 g/m²
Measured thickness : around 0.6 mm
Colours : various

TEST REPORT : N° 16-00741 E1-V1 on the 26th April, 2016

TESTS : Electrical burner test

CLASSIFICATION : **M 2**

**Valid classification for any application for which the product is not subjected to the CE marking of the
Construction products**

CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France on the 26th April, 2016

Head of Quality Management Test and trials
Jean-Marc ORAISON



ACCREDITATION
N° 1-0101 et
N° 1-0513
PORTÉE
COMMUNIQUÉE
SUR DEMANDE