

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-26-000264

Only the original French edition of this procès-verbal is authentic.  
*Seule l'édition originale en français du présent procès-verbal fait foi.*

The French PROCES VERBAL is valid for 5 years starting on June 16<sup>th</sup>, 2026

<b>Applicant</b>	SAINT CLAIR TEXTILES 415 Avenue de Savoie 38110 SAINT CLAIR DE LA TOUR France
<b>SIREN</b>	381424712
<b>Sample reference</b>	SUNBLOCK
<b>Brief description provided by the applicant</b>	Polyester backing coated with PVC, at a rate of 670 g/m <sup>2</sup> on both sides, with in the mass flame-retardant.
<b>Mass per unit area determined by the laboratory</b>	852 g/m <sup>2</sup> ± 10%
<b>Thickness measured by the laboratory</b>	0,63 mm ± 10%
<b>Colour</b>	All colours
<b>End-use condition</b>	Pergolas, Awnings, Glamping, Shade Sails, Tents

**Standard of tests:**

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials

**Classification obtained in the official Procès Verbal:**

M2

**Valid for any application for which the product is not subjected to the CE marking.**

**Durability of the classification (NFP 92-512: 1986):** Supposedly unlimited

*Taking into account the criteria resulting from the tests described in the test report n°EFR-26-000264-BE-A from June 19<sup>th</sup>, 2026.*

*This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.*

*Efectis France is approved for fire reaction tests according to the Decree of December 29<sup>th</sup>, 2016 amending the Decree of February 5<sup>th</sup>, 1959.*

Saint-Aubin, on June 19<sup>th</sup>, 2026