

**For the Account of**

Saint Clair Textiles
415 Avenue d Savoie
F-38110 Saint-Clair-de-la-Tour France

Client's Identification

SUNVIEW 05

CERTIFICATE OF TESTING**TEST PERFORMED** NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films 2023 – Test #1**TEST RESULTS**

Specimen	Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)
1	22.9	22.5	2	0.0	0.0
2	23.2	18.8	19	0.0	0.0
3	23.0	23.0	0	0.0	0.0
4	23.2	22.5	3	0.0	0.0
5	23.2	14.5	38	0.0	0.0
6	23.1	22.9	1	0.0	0.0
7	23.3	19.4	17	0.0	0.0
8	23.3	23.0	1	0.0	0.0
9	23.3	22.8	2	0.0	0.0
10	23.2	18.1	22	0.0	0.0
Average	23.2	20.8	11	0.0	0.0

NOTES

Approximate weight (oz./sq. yd) 11.4

Standard Deviation 12.9

Mean + 3 SD 49.7

Product Configuration Single Layer Multi Layer
Material Tested Initially
Test Environment 70 ±4°F, 50 ±5% Relative Humidity
Conditioning Oven at 220°F (30 minutes) 70 ±4°F & 65 ±5%RH for 24 hours
Sampling As Received
Intended End-use Drapery

ACCEPTANCE CRITERIA*Afterflame is required to be recorded; however, it is not factored into the Acceptance Criteria*

1. Drip burn (Flaming Drip) shall not exceed an average of 2 seconds per specimen for the sample of 10 specimens
2. Mass Loss shall not exceed 40% for the average of 10 specimens
3. Individual specimen mass loss shall not exceeds mean + 3 SD

CONCLUSION Based on the above Results and Acceptance Criteria, the item tested:

Complies
 Does Not Comply
 Testing of 10 additional specimens is required

CERTIFICATION I certify that the above results were obtained after testing specimen in accordance with the procedures and equipment specified by the standard stated above.

Authorized Signature

Date Order Completed: 01/08/2026