

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-26-004204

Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on September 22nd, 2026

Applicant	SAINT CLAIR TEXTILES 415 avenue de Savoie 38110 SAINT CLAIR DE LA TOUR France
SIREN	381424712
Sample reference	SUNVIEW 12
Brief description provided by the applicant	Polyester mesh, coated with PVC, at a rate of 215 g/m ² , with in the mass fire-retardant.
Mass per unit area determined by the laboratory	375 g/m ² ± 10%
Thickness measured by the laboratory	0,50 mm ± 10%
Colour	All colours
End-use condition	Sun protection

Standard of tests:

- NF P 92-507 (2004) - Building - Interior fitting materials - Classification according to their reaction to fire
- NF P 92-503 (1995) - Reaction to fire tests - Electrical burner test used for flexible materials

Classification obtained in the official Procès Verbal:

M2

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-26-004204-BE-A from September 25th, 2026.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Saint-Aubin, on September 25th, 2026